



Analysis Report



District Level Water Analysis Laboratory, U.P. Jal Nigam (Gramin) Saharanpur 247001
Address-Office of Executive Engineer, Construction Unit U.P. Jal Nigam Near Gandhi Park District Saharanpur -247001

Certificate No. TC-10067

Rept No UPJN/SRE/540 Issue Date-01.09.2023 Page No. 1

Remark Customer Details

Office Name and Address Office Of Executive Engineer (NagarNigam) Gurudwara Road Saharanpur-247001
Ref Letter No & Date Office of Jal Kal Vibhag Nagar Nigam 25/08/2023

Basic details of sample

District	Saharanpur	Block	NA
Gram Panchayat	NA	Village	NA
Habitation	Near Mission Compound	Location	St. Mary's Academy
Water Source	DeepTubewell	Sample No.	1
Quantity of Sample	02 L	Date of Sample Collection	25.08.2023
Receiving Date	25.08.2023	Sample Collector	Rishi Pal Saini Nagar Nigam
Sample Depositer	Parvindra Kumar	Sampling Method	IS:17614:PART 1:2021
Analysis Start Date	28.08.2023	Analysis Completion Date	29.08.2023

Technical Data of Analysis

S.No.	Analysed Parameters	Units of Measurement	Observed Value	Specified Values as per IS 10500:2012		Ref. Method of Analysis
				Acceptable Limit	Permissible Limit	
1	2	3	4	5	6	7
1	pH		7.52	6.5-8.5	6.5-8.5	IS 3025 (Part 11) :2017
2	Turbidity	(NTU)	3.6	1.00	5.00	IS 3025 (Part 10) : 2017
3	TDS	(mg/L)	427	500	2000	IS 3025 (Part 16) : 2017
4	Chloride	(mg/L)	40	250	1000	IS 3025 (Part 32) : 2019
5	Total Alkalinity	(mg/L)	300	200	600	IS 3025 (Part 23) : 2019
6	Total Hardness	(mg/L)	380	200	600	IS 3025 (Part 21) : 2019
7	Fluoride	(mg/L)	0.218	1	1.5	APHA 23 Edition-4500-F Method C(Electrode Method):2017

Note 1. This Certificate refers only to the particular sample(s) submitted for testing.
2. This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained
3. The test results reported in this certificate are valid at the time of and under the stated conditions of measurements.
4. Sample will be stored up to 15 days (in case of non perishable items only) from the date of issue of tests reports unless otherwise specified.

Amit Kumar
(Lab Assistant)

Deeksha Goyal
(Deeksha Goyal)
Technical Manager

Result:
Pass (✓)
Fail ()

Laboratory Contact Details:
Name: Deeksha Goyal (Chemist)
Email Id: deekshaaggarwal5732@gmail.com
Mob. No: 7302305330

St. Mary's Academy
Saharanpur
Manager
Principal

Annexure C

Appendix-XIII

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. UPJN/SRE/540

Dated: 02.09.2023

It is certified that an inspection team headed by Mr. Amit Tomar
(Name of Officers with designation) from Sanitary and Food Inspector
(Name of Department/ Office) inspected the St. Mary's Academy Mission Compound Bze
(Name & Address of the school) on 04-09-23 (date of inspection), checked the water test report submitted by the school and found that the school has potable drinking water for students and staff of the institution and is having provision for running water in the toilets and maintaining hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

The above is valid for a period of 7.....

Signature with Seal:
Name :
Designation :



Assistant Engineer of
the Govt. Public Health Department (PHED)/
Authorised officer of the Local Body

Name & Address of the Office / Department :

To

ST. MARY'S ACADEMY
MISSION COMPOUND
SAHARANPUR - 247001
(Name & Address of the Institution)

* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.